



- NOTES:
1. CASING TO EXTEND 4' MIN. EACH SIDE OF PAVEMENT.
 2. CARRIER PIPE SHALL BE RESTRAINED JOINT PIPE UNLESS OTHERWISE WAIVED BY THE MANAGER, DEPENDING ON THE LENGTH OF CASING.
 3. CASING TO BE SIZED PER REQUIREMENTS OF SECTION 7 OF THE SEMINOLE COUNTY WATER AND SEWER STANDARDS.
 4. PLACEMENT OF SPACERS SHALL BE REQUIRED PER THE MANUFACTURER'S SPECIFICATIONS.
 5. CASING END SEAL AND SPACERS MUST BE FROM A MANUFACTURER LISTED IN APPENDIX D OF THE WATER AND SEWER STANDARDS OR AN APPROVED EQUAL.

BORE & JACK DETAIL